



EBOP Domestic Lifestyle Tank Testing

Date	cBOD (mg/L)		SS (mg/L)		TN, 5 Day Average (mg/L)	
	Raw	Treated	Raw	Treated	Raw	Treated
5-Jul-05	209	6	174	13		
6-Jul-05	206	7	158	15		
7-Jul-05	264	12	460	17		
8-Jul-05	212	7	179	10		
9-Jul-05	339	7	412	14		
10-Jul-05	231	5	210	11		
11-Jul-05	253	5	330	14		
30-Aug-05	221	<2	633	2	51	28
31-Aug-05	106	2	234	3	44	27
1-Sep-05	127	2	219	3	44	25
2-Sep-05	427	3	1067	3	47	23
3-Sep-05	107	2	433	3	46	22
4-Sep-05	315	4	397	3	55	22
7-Nov-05	380	4	445	5	79	16
8-Nov-05	56	5	48	2	72	14
9-Nov-05	112	5	36	5	68	14
10-Nov-05	56	5	53	3	51	14
11-Nov-05	108	6	232	6	48	16
12-Nov-05	133	4	105	6	39	16
13-Nov-05	121	6	148	10	44	16
9-Jan-06	212	3	306	4	55	16
10-Jan-06	56	3	60	4	56	17
11-Jan-06	112	5	36	5	115	19
12-Jan-06	81	3	146	7	90	20
13-Jan-06	120	5	108	9	37	21
14-Jan-06	257	4	336	13	88	24
15-Jan-06	246	6	Not Available		45	26
27-Feb-06	281	3	415	10	72	23
28-Feb-06	356	3	306	8	70	23
1-Mar-06	363	3	610	8	75	23
2-Mar-06	325	7	508	17	79	23
3-Mar-06	384	7	407	9	83	23
4-Mar-06	246	3	205	5	83	24
5-Mar-06	216	2	344	7	84	24
24-Apr-06	281	<2	415	1	70	20
26-Apr-06	356	<2	306	2	69	18
27-Apr-06	363	3	610	2	66	17
28-Apr-06	325	<2	508	2	64	15
29-Apr-06	384	<2	407	2	66	14
30-Apr-06	246	<2	205	2	70	14

**Total
Average**

**157.00
3.93**

**263.36
6.58**

BOD and SS results taken only periodically during trial
Plant not set up correctly for Denitrification for first set of TN results